# Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
Wisconsin State Laboratory ID# 105-10117
Wisconsin DNR Lab ID #399073400

**Client:** Northome School ISD #363

**Address:** Northwest Service CO-OP
114 First Street West
Thief River Falls, MN 56701

**Report Number:** 22-03432
**Sample Receipt Date:** 4/15/22
**Sample Prep. Date:** 4/15/22
**Sample Prep. Time:** 10:30
**Report Issue Date:** 4/20/22

Twin City Water Clinic Inc.
617 13th Avenue South
Hopkins, MN 55343
Phone: (952)935-3556
Fax: (952)935-5077

X No samples were subcontracted; or the above test result(s) with'**' designation were produced by a subcontracted laboratory. [Laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

| Laboratory | Analyte | Sample | Parameter | Sample Collection | | Sample Analysis | | Test | |
|---|---|---|---|---|---|---|---|---|---|
| Sample ID | | Location | | Date | Time | Date | Time | Results | Units |
| 22-03432 | Lead | Head Start Classroom | Drinking Water | 04/14/22 | 07:30 | 04/20/22 | 12:04 | <2.0 | µg/L |
| 22-03433 | Lead | Head Start Classroom | Drinking Water | 04/14/22 | 07:30 | 04/20/22 | 12:21 | <2.0 | µg/L |

Approved methods used in analyzing the samples listed above have the following reporting levels:
SM3113 - Lead, 2.0 µg / L
Maximum contaminant level: Lead, 15.0 µg /L

Sample Collected by: _X_ Client __ TCWC

Sample Temp.: 17° C

Notes:

Discussion:

Approved By:

Bill Van Arsdale
Laboratory Manager

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.