twin city water clinic

617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
info@twincitywaterclinic.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE:
9/14/2026

REPORT #:
26-09300

CLIENT/CLIENT ADDRESS
Northwest Service Co-Op
114 1st St W
Thief River Falls, MN 56701

SCHOOL/ADDRESS
Northome School
11731 Hwy 1
Northome, MN 56661

SAMPLE INFORMATION

RECEIPT DATE/TIME:
9/4/2026 at 15:00

TEMP OF SAMPLE UPON RECEIPT:
21 °C

COLLECTED BY:
☐ TCWC ☑ CLIENT ☐ Other

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	ACTION LEVEL*	RESULT
26-09300	*Lead*	Kitchen Prep Station - Faucet	8/28/2026	07:56	9/11/2026	11:04	SM3113B-93	5 µg/L	**3.41 µg/L**
26-09301	*Lead*	Kitchen Sink North Wall Left Side - Faucet	8/28/2026	07:59	9/11/2026	11:10	SM3113B-93	5 µg/L	**12.2 µg/L**
26-09302	*Lead*	Kitchen Sink North Wall Right Side - Faucet	8/28/2026	08:03	9/11/2026	11:16	SM3113B-93	5 µg/L	**18.3 µg/L**
26-09303	*Lead*	by Big Gym - Drinking Fountain	8/28/2026	08:10	9/11/2026	11:22	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-09304	*Lead*	Commons - Drinking Fountain	8/28/2026	08:15	9/11/2026	11:28	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-09305	*Lead*	Nurse Bathroom - Sink	8/28/2026	08:18	9/11/2026	11:34	SM3113B-93	5 µg/L	**5.98 µg/L**
26-09306	*Lead*	Office - Drinking Fountain	8/28/2026	08:21	9/11/2026	11:40	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-09307	*Lead*	Office Break Room - Faucet	8/28/2026	08:23	9/11/2026	11:46	SM3113B-93	5 µg/L	**2.84 µg/L**
26-09308	*Lead*	Lower Level Hall - Drinking Fountain	8/28/2026	08:27	9/11/2026	12:04	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-09309	*Lead*	Upper Level Hall - Drinking Fountain	8/28/2026	08:30	9/11/2026	12:23	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-09310	*Lead*	Home Ec. Sink Left #1 - Faucet	8/28/2026	08:34	9/11/2026	12:29	SM3113B-93	5 µg/L	**6.63 µg/L**
26-09311	*Lead*	Home Ec. Sink #2 - Faucet	8/28/2026	08:36	9/11/2026	12:38	SM3113B-93	5 µg/L	**29.5 µg/L**
26-09312	*Lead*	Home Ec. Sink #3 - Faucet	8/28/2026	08:38	9/11/2026	12:44	SM3113B-93	5 µg/L	**3.31 µg/L**
26-09313	*Lead*	Home Ec. Sink #4 - Faucet	8/28/2026	08:40	9/11/2026	12:50	SM3113B-93	5 µg/L	**12.5 µg/L**
26-09314	*Lead*	Small Gym - Drinking Fountain	8/28/2026	08:43	9/11/2026	12:56	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-09315	*Lead*	Big Gym South - Drinking Fountain	8/28/2026	08:47	9/11/2026	13:02	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-09316	*Lead*	Big Gym North - Drinking Fountain	8/28/2026	08:49	9/11/2026	13:08	SM3113B-93	5 µg/L	**<2.00 µg/L**

*The action level is determined by MN Statute 121A.335.

NOTES

APPROVED BY:
Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119
The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.