twin city water clinic

617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
info@twincitywaterclinic.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE:	CLIENT/CLIENT ADDRESS	SCHOOL/ADDRESS
10/14/2026	Northwest Service Co-Op 114 1st St W Thief River Falls, MN 56701	Northome School 11731 Hwy 1 Northome, MN 56661
REPORT #:		
26-10404		

SAMPLE INFORMATION

RECEIPT DATE/TIME:	TEMP OF SAMPLE UPON RECEIPT:	COLLECTED BY:
10/05/2026 at 11:00	19 °C	☐ TCWC ☑ CLIENT ☐ Other

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	ACTION LEVEL*	RESULT
26-10404	*Lead*	Kitchen Sink North Wall Left Side - Faucet	10/02/2026	6:30	10/13/2026	15:04	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-10405	*Lead*	Kitchen Sink North Wall Right Side - Faucet	10/02/2026	6:30	10/13/2026	15:10	SM3113B-93	5 µg/L	**3.05 µg/L**
26-10406	*Lead*	Nurse Bathroom - Sink	10/02/2026	6:31	10/13/2026	15:16	SM3113B-93	5 µg/L	**2.29 µg/L**
26-10407	*Lead*	Home Ec. Sink Left #1 - Faucet	10/02/2026	6:40	10/13/2026	15:22	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-10408	*Lead*	Home Ec. Sink #2 - Faucet	10/02/2026	6:42	10/13/2026	15:28	SM3113B-93	5 µg/L	**<2.00 µg/L**
26-10409	*Lead*	Home Ec. Sink #4 - Faucet	10/02/2026	6:43	10/13/2026	15:34	SM3113B-93	5 µg/L	**<2.00 µg/L**

*The action level is determined by MN Statute 121A.335.

NOTES

APPROVED BY:

Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.