

Water Sampling Data Sheet

School: Sunnyside

Sample ID	Location	Type	Date	Results	Units
RW-SS-K1	Kitchen	Kettle	10/18/2018	3.2	ug/L
RW-SS-K2	Kitchen	Kettle	10/18/2018	6.3	ug/L
RW-SS-SP2	Kitchen	Sprayer	10/18/2018	0.68	ug/L
RW-SS-S1	Kitchen	Sink	10/18/2018	1.5	ug/L
RW-SS-Café-DF	Cafeteria	Drinking Fountain	10/18/2018	0.41	ug/L
RW-SS-SL-1	Staff Lounge	Sink	10/18/2018	3.3	ug/L
RW-SS-144-S	Room 144	Sink	10/18/2018	3	ug/L
RW-SS-145-S	Room 145	Sink	10/18/2018	1.9	ug/L
RW-SS-O157-DF	Outside 157	Drinking Fountain	10/18/2018	0	ug/L
RW-SS-O157-BF	Outside 157	Bottle Filler	10/18/2018	0	ug/L
RW-SS-149-S	Room 149	Sink	10/18/2018	3.8	ug/L
RW-SS-146-S	Room 146	Sink	10/18/2018	3.4	ug/L
RW-SS-150-S	Room 150	Sink	10/18/2018	3.2	ug/L
RW-SS-151-S	Room 151	Sink	10/18/2018	6.2	ug/L
RW-SS-154-S	Room 154	Sink	10/18/2018	5.8	ug/L
RW-SS-155-S	Room 155	Sink	10/18/2018	4.6	ug/L
RW-SS-156-S	Room 156	Sink	10/18/2018	4	ug/L
RW-SS-185-S	Room 185	Sink	10/18/2018	3.3	ug/L
RW-SS-186-S	Room 186	Sink	10/18/2018	4.7	ug/L
RW-SS-181-S	Room 181	Sink	10/18/2018	10.7	ug/L
RW-SS-O181-TDF	Outside 181 - Tall	Drinking Fountain	10/18/2018	0	ug/L
RW-SS-O181-SDF	Outside 181 - Short	Drinking Fountain	10/18/2018	0	ug/L
RW-SS-O181-BF	Outside 181	Bottle Filler	10/18/2018	0	ug/L
RW-SS-182-S	Room 182	Sink	10/18/2018	11.9	ug/L
RW-SS-183-S	Room 183	Sink	10/18/2018	3.9	ug/L
RW-SS-188-S	Room 188	Sink	10/18/2018	5.3	ug/L
RW-SS-189-S	Room 189	Sink	10/18/2018	2	ug/L
RW-SS-184-S	Room 184	Sink	10/18/2018	2.4	ug/L
RW-SS-190-S	Room 190	Sink	10/18/2018	1.8	ug/L
RW-SS-111-TDF	Room 111 - Tall	Drinking Fountain	10/18/2018	0	ug/L
RW-SS-111-SDF	Room 111 - Short	Drinking Fountain	10/18/2018	0	ug/L
RW-SS-111-BF	Room 111	Bottle Filler	10/18/2018	0	ug/L
RW-SS-126-S	Room 126	Sink	10/18/2018	13.3	ug/L
RW-SS-122-S	Room 122	Sink	10/18/2018	2	ug/L
RW-SS-127-S	Room 127	Sink	10/18/2018	4.8	ug/L
RW-SS-O127-TDF	Outside Room 127 - Tall	Drinking Fountain	10/18/2018	0	ug/L
RW-SS-O127-SDF	Outside Room 127 - Short	Drinking Fountain	10/18/2018	0	ug/L
RW-SS-O127-BF	Outside Room 127	Bottle Filler	10/18/2018	0	ug/L
RW-SS-130-S	Room 130	Sink	10/18/2018	5.8	ug/L