

Water Sampling Data Sheet  
School: Red Wing High School

Sample Number	Location	Type	Date	Results
1	Kitchen - 1	Sink	2/7/2023	<2.0
2	Kitchen - 1	Kettle	2/7/2023	6.28
3	Kitchen	Tilt Skillet	2/7/2023	3.2
4	Kitchen - 2	Kettle	2/7/2023	2.22
5	Kitchen - 2	Sink	2/7/2023	<2.0
6	Kitchen - 3	Sink	2/7/2023	<2.0
7	Staff Dining Room	Sink	2/7/2023	<2.0
8	Cafeteria	Drinking Fountain	2/7/2023	<2.0
9	Cafeteria	Bottle Filler	2/7/2023	<2.0
10	Next to Little Theater - Left	Drinking Fountain	2/7/2023	<2.0
11	Next to Little Theater - Right	Drinking Fountain	2/7/2023	<2.0
12	Next to Little Theater	Bottle Filler	2/7/2023	<2.0
13	District Office Break Room	Sink	2/7/2023	7.83
14	District Office Break Room	Spout	2/7/2023	<2.0
15	Weight Room	Drinking Fountain	2/7/2023	<2.0
16	Across from Weight Room - Left	Drinking Fountain	2/7/2023	<2.0
17	Across from Weight Room - Right	Drinking Fountain	2/7/2023	<2.0
18	Next to Gym - Left	Drinking Fountain	2/7/2023	<2.0
19	Next to Gym - Right	Drinking Fountain	2/7/2023	<2.0
20	Next to Gym	Bottle Filler	2/7/2023	<2.0
21	Boys Locker Room	Drinking Fountain	2/7/2023	<2.0
22	Training Room	Sink	2/7/2023	<2.0
23	Girls Locker Room	Drinking Fountain	2/7/2023	<2.0
24	Outside Hovda - Left	Drinking Fountain	2/7/2023	<2.0
25	Outside Hovda - Right	Drinking Fountain	2/7/2023	<2.0
26	Outside Front Office - Left	Drinking Fountain	2/7/2023	<2.0
27	Outside Front Office - Right	Drinking Fountain	2/7/2023	<2.0
28	Front Office Work Room	Sink	2/7/2023	<2.0
29	Nurse's Office	Sink	2/7/2023	<2.0
30	1st Floor H Pod	Sink	2/7/2023	3.94
31	1st Floor H Pod	Drinking Fountain	2/7/2023	<2.0
32	Outside H Pod 1st Floor	Drinking Fountain	2/7/2023	<2.0
33	Outside H Pod 1st Floor	Bottle Filler	2/7/2023	<2.0
34	J108	Sink	2/7/2023	5.44
35	1st Floor J Pod	Sink	2/7/2023	6.58
36	Outside H Pod 2nd Floor	Drinking Fountain	2/7/2023	<2.0
37	2nd Floor H Pod	Drinking Fountain	2/7/2023	<2.0
38	2nd Floor H Pod	Sink	2/7/2023	<2.0
39	Outside J Pod 2nd Floor - Left	Drinking Fountain	2/7/2023	<2.0
40	Outside J Pod 2nd Floor - Right	Drinking Fountain	2/7/2023	<2.0
41	Outside J Pod 2nd Floor	Bottle Filler	2/7/2023	<2.0
42	2nd Floor J Pod	Drinking Fountain	2/7/2023	<2.0

43	2nd Floor J Pod	Sink	2/7/2023	5.34
44	J100	Sink	2/7/2023	5.99
45	K105	Sink	2/7/2023	<2.0
46	K105 Bathroom	Sink	2/7/2023	<2.0
47	K103	Sink	2/7/2023	<2.0
48	K102 FACS - 1	Sink	2/7/2023	<2.0
49	K102 FACS - 2	Sink	2/7/2023	<2.0
50	K102 FACS - 3	Sink	2/7/2023	<2.0
51	K102 FACS - 4	Sink	2/7/2023	<2.0
52	K102 FACS - 5	Sink	2/7/2023	<2.0
53	K102 FACS - 6	Sink	2/7/2023	<2.0
54	K101	Sink	2/7/2023	5.28
55	Outside Coffee Shop - Left	Drinking Fountain	2/7/2023	<2.0
56	Outside Coffee Shop - Right	Drinking Fountain	2/7/2023	<2.0