

Lead in Water Testing Results

Red Wing Public Schools

Burnside Elementary

On December 28th, 2023 Burnside Elementary's drinking water was tested for concentration of lead.

The following water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these sources at this time.

LOCATION	SOURCE	RESULT
Room 104 (left)	BOTTLE FILLER	0
Room 104 (right)	BOTTLE FILLER	0
Room 104 (left)	SINK	0
Room 104 (right)	SINK	3.64
Hallway outside Room 115	FOUNTAIN	0
Room 115	SINK	4.37
Room 116	SINK	0
Room 117	SINK	2.57
Hallway outside Room 119	BOTTLE FILLER	0
Hallway outside Room 119 (left)	FOUNTAIN	0
Hallway outside Room 119 (right)	FOUNTAIN	0
Room 119	SINK	0
Room 127	SINK	4.82
Hallway outside Room 130	FOUNTAIN	0
Hallway outside Room 147	BOTTLE FILLER	0
Hallway outside Room 147 (left)	FOUNTAIN	0
Hallway outside Room 147 (right)	FOUNTAIN	0
Hallway outside Room 157	BOTTLE FILLER	0
Hallway outside Room 157 (left)	FOUNTAIN	0
Hallway outside Room 157 (right)	FOUNTAIN	0
Room 160	SINK	4.98
Cafeteria	BOTTLE FILLER	0
Cafeteria	FOUNTAIN	0
Kitchen	SINK	2.09
Kitchen	SPRAYER	0

The following water sources tested above the action level of 5 ppb. To reduce lead exposure, actions listed below were taken.

LOCATION	SOURCE	RESULT	ACTION
Room 103	SINK	23.4	Identified as handwashing sink only
Room 107	SINK	12.8	Identified as handwashing sink only
Room 110	SINK	10.8	Identified as handwashing sink only
Room 112	SINK	8.88	Identified as handwashing sink only
Room 113	SINK	9.53	Identified as handwashing sink only
Room 118	SINK	14.6	Identified as handwashing sink only

Room 120	SINK	10.7	Identified as handwashing sink only
Room 121	SINK	8.45	Identified as handwashing sink only
Room 125	SINK	9.70	Identified as handwashing sink only
Room 129	SINK	14.8	Identified as handwashing sink only
Room 142	SINK	36.2	Identified as handwashing sink only
Room 143	SINK	23.5	Identified as handwashing sink only
Room 145	SINK	19.9	Identified as handwashing sink only
Room 146	SINK	11.3	Identified as handwashing sink only
Room 147	SINK	12.7	Identified as handwashing sink only
Room 148	SINK	7.59	Identified as handwashing sink only
Room 149	SINK	10.8	Identified as handwashing sink only
Room 150	SINK	6.34	Identified as handwashing sink only
Room 156	SINK	8.52	Identified as handwashing sink only
Room 157	SINK	18.5	Identified as handwashing sink only
Room 158	SINK	19.1	Identified as handwashing sink only