

Lead in Water Testing Results

Red Wing Public Schools

Colvill Family Center

On December 28th, 2023 Colvill Family Center's drinking water was tested for concentration of lead.

The following water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these sources at this time.

LOCATION	SOURCE	RESULT
Hallway outside Room 102	SINK	0
Room 110	FOUNTAIN	0
Room 119	SINK	1.63
Room 212 (left)	FOUNTAIN	0
Room 212 (right)	FOUNTAIN	2.91
Room 216	FOUNTAIN	4.96
Room 218	FOUNTAIN	1.18
Room 308	FOUNTAIN	0
Room 309	FOUNTAIN	0
Room 309	SINK	2.42
Room 311	SINK	0
Kitchen	SINK	4.98
Kitchen	SPRAYER	3.33

The following water sources tested above the action level of 5ppb. To reduce lead exposure, actions listed below were taken.

LOCATION	SOURCE	RESULT	ACTION
Room 218	SINK	8.22	Identified as handwashing sink only
Room 219	SINK	7.70	Identified as handwashing sink only
Room 308	SINK	8.27	Identified as handwashing sink only