

Lead in Water Testing Results

Prairie Island Arena and Pole Barn

370 Guernsey Lane, Red Wing, MN 55066

On July 30th, 2026 Prairie Island Arena and the Pole Barn's consumable water sources were tested for the concentration of lead. Sampling was conducted by Wendy German of Meridian Consulting Group and were brought to Twin Cities Water Clinic for the lab work and results.

All water sources tested less than our action level of 5 parts-per-billion (ppb). No action is needed.

Location	Source	Result
Arena – lower level	Fountain	< 2.00 ppb
Arena – lower level	Bottle Filler	< 2.00 ppb
Pole Barn – Office	Dispenser	< 2.00 ppb
Pole Barn – Bathroom	Sink	< 2.00 ppb



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
info@twincitywaterclinic.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE:

8/10/2026

REPORT #:

26-07611

CLIENT/CLIENT ADDRESS

Meridian Consulting Group
16620 61st Ave N
Plymouth, MN, 55446

SCHOOL/ADDRESS

Prairie Island Arena & Pole Barn
370 Guernsey Lane
Red Wing, MN 55066

SAMPLE INFORMATION

RECEIPT DATE/TIME:

7/30/2026 at 11:30

TEMP OF SAMPLE UPON RECEIPT:

20 °C

COLLECTED BY:

☐ TCWC

☒ CLIENT

☐ Other

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	ACTION LEVEL*	RESULT
26-07611	Lead	Arena Drinking Fountain	7/30/2026	8:30	7/31/2026	11:44	SM3113B-93	5 µg/L	<2.00 µg/L
26-07612	Lead	Arena Bottle Filler	7/30/2026	8:30	8/3/2026	11:19	SM3113B-93	5 µg/L	<2.00 µg/L
26-07613	Lead	Pole Barn Dispenser	7/30/2026	8:30	8/3/2026	11:25	SM3113B-93	5 µg/L	<2.00 µg/L
26-07614	Lead	Pole Barn Bathroom Sink	7/30/2026	8:30	8/3/2026	11:31	SM3113B-93	5 µg/L	<2.00 µg/L

*The action level is determined by MN Statute 121A.335.

NOTES

APPROVED BY:

Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.